



产品认证证书

证书编号: CQC20107279179

II 型自愿认证

申请人名称及地址

TopWorx Inc.
3300 Fern Valley Road, Louisville, KY 40213, USA

制造商名称及地址

TopWorx Inc.
3300 Fern Valley Road, Louisville, KY 40213, USA

生产企业名称及地址

TopWorx Inc. (V059165)
3300 Fern Valley Road, Louisville, KY 40213, USA

产品名称和系列、规格、型号

磁性开关

52M: Ui:250V;Uimp:2.5kV;AC-12:Ue/Ie:AC120V/3A;DC-12:Ue/Ie:DC24V/2A;Ith: 4A;外壳防护等级:IP66; 型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

产品型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

发证日期: 2020 年 12 月 21 日 有效期至: 2025 年 12 月 21 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0445566



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20107279179

Type II CQC Certification

NAME AND ADDRESS OF THE APPLICANT

TopWorx Inc.
3300 Fern Valley Road, Louisville, KY 40213, USA

NAME AND ADDRESS OF THE MANUFACTURER

TopWorx Inc.
3300 Fern Valley Road, Louisville, KY 40213, USA

NAME AND ADDRESS OF THE FACTORY

TopWorx Inc. (V059165)
3300 Fern Valley Road, Louisville, KY 40213, USA

PRODUCT NAME, MODEL AND SPECIFICATION

Magnetic Switch

52M: Ui:250V;Uimp:2.5kV;AC-12:Ue/Ie:AC120V/3A;DC-12:Ue/Ie:DC24V/2A;Ith: 4A;IP66; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020 .

Valid from: Dec.21,2020

Valid until: Dec.21,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0445566



产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC20107279179

纸 号: 445566

型号解释:

Go Switch Models 52M

E.g. Model No.: 52M - 5 6 1 0 - D

① ② ③ ④ ⑤ ⑥

① Model 型号

52M: 316/316L stainless steel, 12mm thread x 45mm long (316 / 316L 不锈钢, 12mm 螺纹 x 45mm 长)

② Sensing Range 感应范围

5: 1.5mm sensing range with ferrous target (1.5mm 感应范围, 含铁靶)

③ Enclosure Material 外壳材料

6: 316/316L stainless steel (316 / 316L 不锈钢)

④ Area Classification* 区域分类

1: CQC/CCC to GB/T14048.5:2017

5. Visual Indication

2: Hi Temperature to 400°F (Wiring option F only) (Hi 温度到 400°F (仅限接线选项 F))

6. Termination 接线/触点

D: M12 Micro Quick-disconnect receptacle, 4-pin (M12 Micro 快速断开插座, 4 针)

B: 4-conductor, PVC insulated cable, 22GA, 1 meter long (4 芯聚氯乙烯绝缘电缆, 22GA, 1 米长)

注: 此附录与证书同时使用时有效。

主任: _____

陆杨



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>