



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 14ATEX2241X** Issue: **6**

4 Equipment: **D-Series Switchbox**

5 Applicant:

- **TopWorx**
- , **Emerson Machinery Equipment (Shenzhen) Co. Ltd.**
- ƒ **Emerson Automation Fluid Control & Pneumatics Poland Sp. z o.o.,**

6 Address:

- **3300 Fern Valley Road, Louisville, KY, 40213, USA**
- , **Fisher Controls Division, Bao Heng Technology Industry Park, Liu Xian 1st Road, District 68, Bao'an District, Shenzhen, China 518101**
- ƒ **Kurczaki, 132, 93 331 Lodz, Poland**

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.



9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2012/A11:2013 EN 60079-11:2012 IEC 60079-31:2013

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:

	II 2G			II 2GD	
	Ex ia IIC T4 Gb	or		Ex ia IIC T4 Gb	or
	Ex ia IIC T6 Gb			Ex ia IIC T6 Gb	
	Ta = -*°C to +*°C			Ex tb IIIC T*°C Db	
				Ta = -*°C to +*°C	

* The temperature class and ambient temperature depends on the electrical devices that are fitted in the Switchbox.

Project Number 80047581

Signed: J A May

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2241X
Issue 6

13 DESCRIPTION OF EQUIPMENT

The D-Series Switchbox is a valve position indicator. A rotating cam activates a number of internal devices that sense the status of the valve position. The Switchbox consists of an enclosure made up of a body and a lid. All models have a visual valve position indicator underneath a plastic dome. The body has threaded entries to allow the installation of cable glands.

The approved internal devices are as shown in the Conditions of Certification.

Enclosures types

Model	Body	Lid	Dome
DXP	Aluminium	Aluminium	Lexan
DXS	Stainless steel	Stainless steel	Lexan
DXR	Resin	Resin	Lexan

Variation 1 - This variation introduced the following changes:

- i. The HART 4-20 mA board was replaced with the HART v7 Module, Sira 16ATEX2342U, this required additions and amendments to the Specific Conditions of Use and Conditions of Manufacture.

Variation 2 - This variation introduced the following changes:

- i. Recognise update to HART v7 Module certificate and thereby modify the Specific Conditions of Use and the Conditions of Manufacture.

Variation 3- This variation introduced the following change:

- i. The change of manufacturing location;
From: Emerson Process Management
Magyarország Kft.
Fisher Controls International LLC,
Holland Faszor 6, Székesfehérvár,
8000, Hungary
To: ASCO Numatics Sp.z o.o.
Kurczaki 132
93 331 Lodz
Poland

Variation 4 - This variation introduced the following change:

- i. The change to the name of the facility in Poland was recognised;
From: ASCO Numatics Sp. z o.o.
To: Emerson Automation Fluid Control & Pneumatics Poland Sp. z o.o.

Variation 5 - This variation introduced the following changes:

- i. Add new ambient ranges for Pepperl +Fuchs Switches and sensors when used without any other components.
- ii. Add T5 temperature code for Simple Switches.
- iii. The Specific Conditions of Use and Conditions of Manufacture were amended.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2241X
Issue 6

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report number	Comment
0	07 July 2015	R70013008A	The release of the prime certificate.
1	17 July 2017	R70095229A	This Issue covers the following changes: <ul style="list-style-type: none"> EC Type-Examination Certificate in accordance with 94/9/EC updated to EU Type-Examination Certificate in accordance with Directive 2014/34/EU. (In accordance with Article 41 of Directive 2014/34/EU, EC Type-Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type-Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.) The introduction of Variation 1.
2	22 October 2018	R70191411A	The introduction of Variation 2.
3	07 March 2019	R70209081A	The introduction of Variation 3.
4	15 October 2019	0844	Transfer of certificate Sira 14ATEX2241X from Sira Certification Service to CSA Group Netherlands B.V.
5	30 July 2020	R80050077A	The introduction of Variation 4.
6	14 September 2020	R80047581A	The introduction of Variation 5.

15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)

15.1 The Switchbox may contain one or more devices covered by the following certificates:

Description	Certificate number
ASCO Electro-valve Module type 3021....IA	INERIS 03ATEX0249X. If fitted, the entity parameters are $U_i = 28V$, $I_i = 300mA$, $P_i = 1.6W$, $C_i = 0$, $L_i = 0$.
Crouzet electro-valve type 81519xxx	LCIE 02ATEX6122X. Refer to certificate for entity parameters specific to the model number.
IFM inductive proximity switch type NE****, NF****, NG****, NI****, NN****, NT****, NS****	PTB 01ATEX2191. Refer to certificate for entity parameters specific to the model number.
Pepperl & Fuchs slot-type initiators, types SJ... & SC...	PTB 99ATEX2219X plus supplement 1. If a T6 temperature class is marked, the input entity parameters to sensors covered by this certificate (if fitted) shall be limited to $U_i = 16V$, $I_i = 25mA$, $P_i = 34mW$ ("type 1" supply).
Pepperl & Fuchs cuboidal inductive sensors, type NJ...	PTB 00ATEX2032X plus Supplements 1 & 2. If a T6 temperature class is marked, the input entity parameters to sensors covered by this certificate (if fitted) shall be limited to $U_i = 16V$, $I_i = 25mA$, $P_i = 34mW$ ("type 1" supply).
Pepperl & Fuchs cylindrical inductive sensors, types NC... & NJ...	PTB 00ATEX2048X plus Supplements 1, 2 & 3. If a T6 temperature class is marked, the input entity parameters to sensors covered by this certificate (if fitted) shall be limited to $U_i = 16V$, $I_i = 25mA$, $P_i = 34mW$ ("type 1" supply).



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2241X
Issue 6

Description	Certificate number
Pepperl & Fuchs SN sensors, type NJ...	PTB 00ATEX2049X plus Supplement 1. If a T6 temperature class is marked, the input entity parameters to sensors covered by this certificate (if fitted) shall be limited to $U_i = 16V$, $I_i = 25mA$, $P_i = 34mW$ ("type 1" supply).
Topworx 4-20 mA Transmitter Module	Sira 12ATEX2192U issue 1. If fitted, the entity parameters are $U_i = 30V$, $P_i = 1.5W$, $C_i = 0$, $L_i = 0$. I_i can be any value from an intrinsically safe source meeting the U_i and P_i requirements.
Topworx HART v7 Module	Sira 16ATEX2342U issue 1. If fitted, the entity parameters are $U_i = 28V$, $I_i = 100mA$, $P_i = 700mW$, $C_i = 11nF$, $L_i = 14\mu H$; $U_o = 7.71V$, $I_o = 100mA$, $P_o = 700mW$, $C_o = 0.993\mu F$, $L_o = 3541\mu H$.
Turck two-wire proximity sensors type ...-.....Y1-...../....	KEMA 02ATEX1090X plus Amendment 1. Refer to certificate for entity parameters specific to the model number.

The installer shall confirm which certified sub-assemblies are contained within the equipment and ensure compliance with the appropriate certificate (with particular reference to entity parameters).

- 15.2 If fitted, the entity parameters for uncertified simple mechanical or reed switches (including the Topworx R2 and R4 Cubes), with or without line fault detection, are $U_i = 30 V$, $I_i = 200 mA$ and $P_i = 0.34 W$ per switch circuit.
- 15.3 If fitted, the entity parameters for the Topworx PN Cube are $U_i = 28 V$, $I_i = 250 mA$ and $P_i = 0.8 W$ per switch circuit.
- 15.4 The supplies to all internal devices shall be treated as separate intrinsically safe circuits.
- 15.5 The DXP version of the Switchbox has an enclosure that is manufactured from aluminium alloy. In rare cases, ignition sources due to impact and friction sparks could occur. This shall be considered when the equipment is installed.
- 15.6 The plastic parts of the Switchbox may generate an ignition-capable level of electrostatic charge. Therefore the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.
- 15.7 When marked for use in flammable dust, the DXR (resin) enclosure shall only be installed where there is a low risk of mechanical damage.
- 15.8 The air pressure to the valve block, when fitted, shall not exceed 10.0 bar.
- 15.9 If the equipment is fitted with a HART v7 Module, it may be supplied with a bonding strap that could be used to connect the shield (screen) of the cable to ground when installed in a metallic enclosure. In this case, the user/installer shall take this into consideration and ensure that earthing arrangements of the final circuitry comply with the requirements of the relevant Code of Practice.
- 15.10 The Switchbox may contain switches/sensors covered by the following certificates, when only one type of switch/sensor is used as per drawing CERT-ES-08677-1 without any other components.



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 14ATEX2241X
Issue 6

Description	Certificate number
Pepperl+Fuchs Switches/Sensors SC, SJ, NC or NJ	PTB 00ATEX2032X PTB 00ATEX2048X PTB 00ATEX2049X PTB 99ATEX2219X

Only one type of switch to be used as per drawing CERT-ES-08677-1 without any other components.

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

Certificate Annexe



Certificate Number: Sira 14ATEX2241X

Equipment: D-Series Switchbox

Applicant:

- TopWorx
- , Emerson Machinery Equipment (Shenzhen) Co. Ltd.
- f Emerson Automation Fluid Control & Pneumatics Poland Sp. z o.o.

Issue 0

Drawing	Sheets	Rev.	Date (Sira stamp)	Description
CERT-E-B0070	1 to 7	G	05 Jun 15	PN Cube schematic, artwork, BoM, marking
CERT-ES-02176-1	1 of 1	2	05 Jun 15	Go-Switch, 4-way, SPDT, assembly
CERT-ES-04311-1	1 to 2	7	05 Jun 15	D-series master assembly
CERT-ES-05107-1	1 of 1	3	22 Jun 15	D-series marking, IECEx/ATEX
CERT-PS-00675	1 to 3	3	05 Jun 15	GO NUMAR simulator board, schematic, BoM, artwork
ES-01005-1	1 to 7	8	20 Dec 13	HART board schematic, parts list & artwork
ES-01006-1	1 of 1	9	20 Dec 13	HART board, assembly
ES-01568-1	1 of 1	3	20 Dec 13	Cube, 4 reed switch, assembly
ES-01569-1	1 to 8	7	20 Dec 13	Cube, 4 reed switch, schematic & artwork
ES-01571-1	1 of 1	5	20 Dec 13	Cube, 2 reed switch, assembly
ES-01572-1	1 to 8	5	20 Dec 13	Cube, 2 reed switch, schematic & artwork
ES-02175-1	1 of 1	3	05 Jun 15	Sub switch 35
ES-02177-1	1 of 1	4	20 Dec 13	L2 wiring diagram
ES-02341-1	1 of 1	1	05 Jun 15	L4 wiring diagram
S-S01-0151	1 of 1	2	05 Jun 15	DPDT mechanical switch
S-S40-0033Y	1 of 1	7	05 Jun 15	PN Cube assembly

Issue 1

Drawing	Sheets	Rev.	Date (Sira stamp)	Description
CERT-ES-04311-1	1 of 1	9	07 Jun 17	D-series master assembly
CERT-ES-05107-1	1 of 1	4	29 Jun 17	D-series marking, IECEx/ATEX

Issue 2 No new drawings were introduced.

Issue 3

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
CERT-ES-05107-1	1 of 1	4	17 Jan 19	NAMEPLATE & NOMENCL.

Issues 4 and 5 No new drawings were introduced.

Issue 6

Drawing	Sheets	Rev.	Date (Stamp)	Title
CERT-ES-08677-1	1 to 7	AA	29 Jul 20	Internal labels

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands